



5 GALLON SHRUB 10" RING  
5'-3" CIRCUMFERENCE = 5 X .4 GPH = 2.0 GPH  
DRIPPERS AT 12" ON CENTER  
SEE PLANS IR-X FOR LATERAL, DRIPPERLINE &  
MANUAL FLUSH VALVE PLACEMENT ON SITE PLAN.

1. INSTALL Netafim TUBING AT 3" BELOW GRADE,
2. STAPLE IN PLACE PER MANUFACTURER'S RECOMMENDATION, BACKFILL, AND SPREAD SURFACE TREATMENT PER LANDSCAPE DETAILS.
3. INSTALL IN ACCORDANCE WITH NETAFIM INSTALLTION GUIDELINES.

NETAFIM SHRUB  
PLAN DETAL  
SCALE: N.T.S.

PROWAG AND  
DOWNTOWN PROJECTS  
NETAFIM SHRUB PLAN DETAIL

DEPARTMENT OF PUBLIC WORKS  
CAPITAL PROJECT MANAGEMENT  
DATE: 6/18/19 DRAWN BY: LPC  
SHEET: 1 OF 1

